



## GAQF.EX26633 Clean-agent Extinguishing System Units

[Page Bottom](#)

### Clean-agent Extinguishing System Units

[See General Information for Clean-agent Extinguishing System Units](#)**MINIMAX FIRE PRODUCTS**

EX26633

2812 N. NORWALK  
BUILDING 10  
SUITE 119  
MESA, AZ 85215 USA

**PRE-ENGINEERED UNIT**, Model Minimax SSP 1230 ILP, Clean Agent Extinguishing System Units containing Novec 1230, stored pressure type, having nominal storage capacities of 3, 7 and 14 lbs. The units are super-pressurized with dry nitrogen to 240 psig at 70°F (21°C) with operating temperatures of +32°F to +130°F (0°C to 54°C). The units are designed for total-flooding protection against Class A surface burning, Class B flammable liquid, and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual Part No. 027650010, issued 11/14. Copies are available from the above Listee.

**AGENT STORAGE CONTAINER ASSEMBLY**

Weight of Agent (lbs)	Part No.
3	B07014009
7	B07014010
14	B07014011

[Last Updated on 2014-11-17](#)[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".