



## UOJZ.S25064 Control Units, System

[Page Bottom](#)

### Control Units, System

[See General Information for Control Units, System](#)

#### MINIMAX USA L L C

2812 N Norwalk St, Bldg 10, Suite 119  
Mesa, AZ 85215 USA

S25064

Model	Type	Type Service	Type Signaling
<b>MX-2002 (c), MX-2002E (c)</b>	L	A, M, SS, WF	March, NC
	AUX	A, M, WF	NC
	RS (PPU)	A, M, SS, WF	DAC, NC, Rev Pol
	P (PPU)	A, M, SS, WF	C, DAC
	CS (PPU)	A, M, SS, WF	DAC
<b>MX-320 #(b)^, MX-320E #(b)(a)^, MX-320C #(b)(a)^</b>	L	A, M, SS, WF	C, MX, NC
	AUX	A, M, WF	NC
	RS (PPU)	A, M, SS, WF	DAC, OT, Rev Pol
	CS (PPU)	A, M, SS, WF	DAC, MX, NC, OT
	P (PPU)	A, M, SS, WF	DAC, MX, NC, OT

L - Local System Type

A - Automatic fire alarm: Thermostats, smoke detectors, etc.

M - Manual fire alarm: Manually-operated boxes

SS - Sprinkler Supervisory: Gate valves, water-level switches, temperature switches, carbon monoxide detectors, residential fire alarm control units, etc.

WF - Waterflow alarm: Waterflow switches

March - March Time

NC - Noncoded

AUX - Auxiliary System Type

RS (PPU) - Remote Station System Type (Protected Premises Unit)

DAC - Digital Alarm Communicator

Rev Pol - Reverse Polarity

P (PPU) - Proprietary System Type (Protected Premises Unit)

C - Coded

CS (PPU) - Central Station System Type (Protected Premises Unit)

MX - Multiplex

OT - Other Transmission Technologies

# - When Local (L) Type, System control unit with additional emergency voice communication, emergency telephone communication and paging.

(a) - When type signaling is OTHER TECHNOLOGIES, see footnote +

(b) - When Type Signaling is Coded (C), see footnote +.

(c) - When Type is Local (L), refer to footnote (2). Noncoded (NC) Type Signaling of Remote Station (PPU) Type, Coded (C) or Digital Alarm Communicator (DAC) Type Signaling, see footnote +. (NC) of Auxiliary (AUX) Type or Rev. Pol. Type Signaling require separately Listed Model 4XTM transmitter module.

+ - Must be employed with additional specific Listed device(s) as indicated in installation instructions and wiring diagrams to provide indicated type service. The installation instructions for the Other Transmission Technologies transmitter will specify the compatible Minimax control unit model.

^ - Complementary Listed under APOU, QVAX, PAZX, SYZV, SYZVC, UUKL, UOJZC, DAYRC.

Last Updated on 2011-07-18

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".