



GAQF.EX15624 Clean Agent Extinguishing System Units

[Page Bottom](#)

Clean Agent Extinguishing System Units

[See General Information for Clean Agent Extinguishing System Units](#)**ROTAREX INC NORTH AMERICA**

EX15624

Westmoreland Technology Park 1
221 Westec Dr
Mt Pleasant, PA 15666-2761 USA

PRE-ENGINEERED UNIT, Model FireDETEC ILP, Clean Agent Extinguishing System Units containing HFC-227ea (FM-200), stored pressure type, having nominal storage capacities of 3, 7 and 14 lbs. The units are super-pressurized with dry nitrogen to 240 psig at 70°F (21°C) with operating temperatures of +32°F to +130°F (0°C to 54°C). The units are designed for total-flooding protection against Class A surface burning, Class B flammable liquid, and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual Part No. 027650004, issued December 2013. Copies are available from the above Listee.

AGENT STORAGE CONTAINER ASSEMBLY

Weight of Agent (lbs)	Part No.
3	B07014500
7	B07014501
14	B07014502

PRE-ENGINEERED UNIT, Model FireDETEC ILP, Clean Agent Extinguishing System Units containing Novec 1230, stored pressure type, having nominal storage capacities of 3, 7 and 14 lbs. The units are super-pressurized with dry nitrogen to 240 psig at 70°F (21°C) with operating temperatures of +32°F to +130°F (0°C to 54°C). The units are designed for total-flooding protection against Class A surface burning, Class B flammable liquid, and Class C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual Part No. 027650005, issued December 2013. Copies are available from the above Listee.

AGENT STORAGE CONTAINER ASSEMBLY

Weight of Agent (lbs)	Part No.
3	B07014503
7	B07014504
14	B07014505

Last Updated on 2014-02-19

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured

under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".